

A Major-Project report on  
**“ZSI supported DSTATCOM for Plug-in Electrical Vehicle  
charging station”**

Submitted to

**Jawaharlal Nehru Technological University, Hyderabad**

In partial fulfilment of the academic requirements for

the award of Degree of

**BACHELOR OF TECHNOLOGY**

In

**ELECTRICAL & ELECTRONICS ENGINEERING**

By

**R. APOORVA**

**206Y5A0222**

**YASMEEN SULTANA**

**206Y5A0226**

**R. SHRUTHI**

**206Y5A0220**

**P. CHANDHANA**

**196Y1A0210**

Under the esteemed guidance of

**Mrs. P. SUCHARITHA** MTEch

**Assistant Professor**



**DEPARTMENT OF ELECTRICAL & ELECTRONICS ENGINEERING**



**2022-23**

*Rajam*

**PRINCIPAL**

Sumathi Reddy Institute of Technology for Women  
Ananthasagar (V), Hasanparthy (M)  
WARANGAL - 506 371 (T.S.)



DEPARTMENT OF ELECTRICAL & ELECTRONICS ENGINEERING



CERTIFICATE

This is to certify that the major project entitled “**ZSI supported DSTATCOM for Plug-in Electrical Vehicle charging station**” submitted to JNTUH carried out by the following students of IV-BTech in the partial fulfillment for the award of the BTech Degree in **Electrical & Electronics Engineering** during the academic year 2022-23.

**R. APOORVA**

YASMEEN SULTANA

R. SHRUTHI

P. CHANDHANA

**206Y5A0222**

206Y5A0226

206Y5A0220

196Y1A0210

  
Guide

Mrs. P. Sucharitha

  
Head of the Dept  
Dr. K. Mahender Sharma





PRINCIPAL

Sumathi Reddy Institute of Technology for Women  
Ananthasagar (V), Hasanparthy (M)  
WARANGAL - 506 371 (T.S.)

## ABSTRACT

In this research work, bidirectional Z source inverter (ZSI) supported DSTATCOM is utilized for Plug-in Electric vehicle (PEV) charging station. The PEV are being replaced by the conventional vehicles to reduce atmospheric pollution and reduce fuel consumption. A ZSI supported DSTATCOM is presented in this research work to improving the power quality of a power system and PEV charging station by using the Instantaneous Symmetrical Component Theory (ISCT) control technique. This system is presented for decreasing harmonics on the supply signals and elimination of large currents in the system due to a fault in the power system and PEV charging station. ZSI acts as a multi converter and has a feature of buck/boost. The power quality aspects are governed by the various standards such as the IEEE-519-1992 standard. The results are extracted using extensive digital simulations performed in MATLAB/SIMULINK environment.



*Rijan*

**Principal**

Sumathi Reddy Institute of Technology for Women  
Ananthasagar (V), Hasanparthy (M)  
WARANGAL - 506 371 (TS)