

A Major-Project report on
**“Reduction Of Harmonics Using Pq Based Hysteresis Controlled
Active Filter”**

Submitted to

Jawaharlal Nehru Technological University, Hyderabad

In partial fulfilment of the academic requirements for

the award of Degree of

BACHELOR OF TECHNOLOGY

In

ELECTRICAL & ELECTRONICS ENGINEERING

By

S. RAJASRI

206Y5A0223

P.JHANSI

196Y1A0211

V. BHAVANI

206Y5A0225

M.JHANSI RANI

206Y5A0216


Under the esteemed guidance of

Mrs. P. SUCHARITHA M.Tech

Assistant Professor



DEPARTMENT OF ELECTRICAL & ELECTRONICS ENGINEERING



2022-23



Rajain
PRINCIPAL

Sumathi Reddy Institute of Technology for Women
Ananthasagar (V), Hasanparthy (M)
WARANGAL - 506 371 (T.S.)



DEPARTMENT OF
ELECTRONICS



ELECTRICAL &
ENGINEERING

CERTIFICATE

This is to certify that the major project entitled “**Reduction Of Harmonics Using Pq Based Hysteresis Controlled Active Filter**” submitted to JNTUH carried out by the following students of IV-B.Tech in the partial fulfillment for the award of the B.Tech Degree in Electrical & Electronics Engineering during the academic year 2022-23.

S. RAJASRI

P.JHANSI

V. BHAVANI

M.JHANSI RANI

206Y5A0223

196Y1A0211

206Y5A0225

206Y5A0216


Guide

Mrs. P. Sucharitha


Head of the Dept

Dr. K. Mahender Sharma




PRINCIPAL

Sumathi Reddy Institute of Technology for Women
Ananthasagar (V), Hasanparthy (M)
WARANGAL - 506 371 (T.S.)

ABSTRACT

A three-phase inverter-based Active Filter (AF) controlled by Instantaneous real and reactive power theory (PQ theory) based hysteresis and PI controllers are present. An Inverter based AF is used to reduce the harmonics caused by non-linear loads in the source voltage and current by injecting the compensating currents. The hysteresis Controller generates the gate pulses required for the operation of AF.

Instantaneous real and reactive power theory (PQ theory) monitors the active and reactive powers and generates the reference current accordingly. PI controller regulates the voltage of the DC link capacitor. The MATLAB Simulink model has been designed for the proposed approach and the THD is reduced significantly.



Rijan

Principal

Sumathi Reddy Institute of Technology for Women
Ananthasagar (V), Hasanparthy (M)
WARANGAL - 506 371 (TS)